

# Artificial Ice Rinks and Indoor Arena Rinks Inventory

Revised: December 2011

BUILDING NAME	ADDRESS	OPER. SEASON	AGE	STATUS	TYPE	TOTAL HP	COMPRESSORS					PUMP DETAILS			CAPITAL IMPROVEMENTS
							40hp	50hp	60hp	75hp	100hp	Type	Pump 1	Pump 2	
<b>SOUTH REGION</b>															
Alexandra Park -A.I.R. Bldg (Harry Gairey)	275 Bathurst St	Nov - Mar	06-Mar-58	Good	Double	200 hp	0	1	0	2	0	Glycol	40 hp	20 hp	New slab, header trench and lights Refrigeration system 2006
Ryerson Park - A.I.R. Bldg	25 Gould St	Nov - Mar	Dec-77	Good	Pleasure	150 hp	0	3	0	0	0	Glycol	30 hp	10 hp	Refrigeration system and floor 1997
Barbara Ann Scott - A.I.R. Bldg (College Park)*	444 Yonge St	Nov - Mar	Oct-82	Good	Pleasure	80 hp	2	0	0	0	0	Brine	20 hp	n/a	New headers 1993
Regent Park North - A.I.R. Bldg	620 Dundas St E	Nov - Mar	Feb-72	Good	Single	100 hp	0	2	0	0	0	Glycol	25 hp	7.5 hp	Refrigeration system and boards 1997
Regent Park South - A.I.R. Bldg	591 Dundas St E	Nov - Mar	Feb-72	Good	Single	100 hp	0	2	0	0	0	Glycol	20 hp	7.5 hp	Refrigeration system and boards 2000
Nathan Phillips Square - A.I.R. Bldg	100 Queen St W	Oct - Mar	Nov-68	Good	Pleasure	150 hp	0	0	0	2	0	Brine	40 hp	40 hp	Refrigeration system and floor 1991
Sherbourne Commons - A.I.R. Bldg*	61 Dockside Rd	Nov - Mar	Dec-10	Good	Pleasure	<b>40 ton refrigeration system</b>					Brine	10 hp	n/a		
<b>EAST REGION</b>															
Greenwood Park - Swimming Pool/A.I.R. Bldg	150 Greenwood Ave	Nov - Mar	1960's	Fair	Double	200 hp	0	1	0	2	0	Brine	25 hp	25 hp	Refrigeration system and boards 1989
Kew Gardens - A.I.R. Bldg*	2075 Queen St E	Nov - Mar	Dec-54	Fair	Single	150 hp	0	0	0	2	0	Brine	15 hp	15 hp	Retrofit 1983, 2 compressors 1991, condenser 1989
Jimmie Simpson C.R.C. - A.I.R. Bldg	870 Queen St E	Nov - Mar	Nov-70	Fair	Single	100 hp	0	2	0	0	0	Brine	25 hp	25 hp	Refrigeration system and boards 1991
Monarch Park - Swimming Pool/A.I.R. Bldg	115 Felstead Ave	Nov - Mar	Dec-60	Good	Single	100 hp	0	2	0	0	0	Glycol	20 hp	7.5 hp	Refrigeration system and boards 1999
Riverdale Park East - Swimming Pool/A.I.R. Bldg	550 Broadview Ave	Nov - Mar	Jan-62	Good	Single	100 hp	0	2	0	0	0	Ammonia**	1.5 hp	1.5 hp	New compressor and condenser 1995
Withrow Park - A.I.R. Bldg	725 Logan Ave	Nov - Mar	1960's	Fair	Single	100 hp	0	2	0	0	0	Brine	25 hp	25 hp	Refrigeration system and boards 1992
<b>WEST REGION</b>															
Wallace Emerson C.R.C. - A.I.R. Bldg	1260 Dufferin St	Nov - Mar	Nov-81	Good	Double	200 hp	0	0	0	0	2	Glycol	40 hp	10 hp	Refrigeration system and floor 2006
Dufferin Grove - A.I.R. Bldg	875 Dufferin St	Nov - Mar	1960's	Good	Double	150 hp	0	0	0	2	0	Brine	25 hp	25 hp	Refrigeration system and boards 1994
Campbell Avenue Playground - A.I.R. Bldg	225 Campbell Ave	Nov - Mar	20-Jan-67	Good	Single	100 hp	0	2	0	0	0	Glycol	20 hp	7.5 hp	2 new compressors 1992, slab, boards and chiller 2002
Christie Pits (Willowvale) - A.I.R. Bldg	750 Bloor St W	Nov - Mar	Dec-78	Good	Single	100 hp	0	2	0	0	0	Glycol	20 hp	7.5 hp	Refrigeration system and boards 2001
Trinity Bellwoods Park - A.I.R. Bldg	709 Queen St W	Nov - Mar	Dec-63	Fair	Single	100 hp	0	2	0	0	0	Glycol	20 hp	7.5 hp	Refrigeration system and boards 2000
<b>NORTH REGION</b>															
Hodgson - A.I.R. Bldg	276 Davisville Ave	Nov - Mar	Jan-81	Good	Double	200 hp	0	1	0	2	0	Ammonia**	3 hp	3 hp	
Otter creek Park - A.I.R. Bldg	140 Cheritan Ave	Nov - Mar	Dec-76	Good	Double	200 hp	0	1	0	2	0	Glycol	40 hp	10 hp	Refrigeration system and boards 2001
Ramsden Park - A.I.R. Bldg	1020 Yonge St	Nov - Mar	Dec-54	Good	Double	200 hp	0	1	0	2	0	Brine	25 hp	25 hp	New rink 1979, New Ammonia system 1991
Rosedale Park - A.I.R. Bldg	20 Scholfield Ave	Nov - Mar	Dec-54	Good	Single	100 hp	0	2	0	0	0	Glycol	20 hp	7.5 hp	Refrigeration system and boards 1998
Dieppe Park - A.I.R. Bldg	455 Cosburn Ave	Nov - Mar	Nov-74	Good	Single	180 hp	0	0	3	0	0	Brine	50 hp	n/a	New boards 1997, Headers 2000
<b>INDOOR ARENAS/RINKS</b>															
East York Arena	888 Cosburn Ave	Sept - May	1951	Fair	Indoor	100 hp	0	2	0	0	0	Brine	30 hp	n/a	Floor and boards 1985, Chiller and condenser 2000
Phil White Arena	443 Arlington Ave	Sept - May	1960's	Fair	Indoor	150 hp	0	0	0	2	0	Brine	25 hp	n/a	New compressors 2008
East York Curling Club	901 Cosburn Ave	Sept - May	1965	Fair	Indoor	60 hp	0	0	1	0	0	Brine	15 hp	n/a	Refrigeration system 2003
<b>* Indicates Freon Refrigeration Plants</b>															
<b>** Ammonia pumps direct expansion floor</b>															