

Artificial Ice Rinks and Indoor Arena Rinks Inventory

Revised: January 2012

BUILDING NAME	ADDRESS	OPER. SEASON	AGE	STATUS	TYPE	TOTAL HP	COMPRESSORS					PUMP DETAILS			CAPITAL IMPROVEMENTS
							30hp	50hp	60hp	75hp	100hp	Type	Pump 1	Pump 2	
RINK LOCATIONS - ETOBICOKE YORK DISTRICT															
West Mall	370 The West Mall	Nov-Mar		Good	D	200					2	Brine	50hp	15hp	
Rennie Park	1 Rennie Terrace	Nov-Mar		Good	D	200		1		2		Glycol	40hp	25hp	
Colonel Samuel Smith	65 Colonel Samuel Smith Park Drive	Nov-Mar		Good	P	200		1		2		Glycol	30hp	15hp	
Westway	175 The West Way	Nov-Mar		Good	S	100		2				Glycol	30hp	15hp	
Sunnydale	50 Amoro Drive	Nov-Mar		Good	S	100		2				Glycol	20hp	7.5hp	
Prince of Wales	1 Third Street	Nov-Mar		Good	S	100		2				Glycol	20hp	7.5hp	
Sir Adam Beck	10 Orianna Drive	Nov-Mar		Good	S	100					1	Glycol	20hp		
High Park	1873 Bloor St W	Nov-Mar		Good	D	100		1		2		Brine	25hp	25hp	
Giovanni Caboto	1369 St. Clair Ave W	Nov-Mar		Good	D	200		1		2		Glycol	30hp	15hp	
Martingrove	400 Martin Grove Rd	Nov-Mar		Good	S	100		2				Glycol	30hp	15hp	
Humber Valley	50 Angelsey Blvd	Nov-Mar		Fair	S	105	1			1		Glycol	20hp	7.5hp	Needs new condenser
Buttonwood	30 Mulham Place	Nov-Mar		Fair	P	75				1		Brine	20hp		Needs new condenser
Valleyfield*	35 The Westway	Nov-Mar		Poor	P	80	1	1				Brine	15h		Freon plant needs complete replacement
Westgrove	15 Redgrave Drive	Nov-Mar		Poor	P	75				1		Brine	20hp		Needs new condenser and chiller
Lambton-Kingsway	37 Marquis Ave	Nov-Mar		Good	P	75				1		Glycol	25hp		
Wedgewood	15 Swan Ave	Nov-Mar		Good	P	100		2				Brine	25hp		
Queensway*	8 Avon Park Drive	Nov-Mar		Poor	P	100		2				Brine	15h		Freon plant needs complete replacement
Summerlea	2 Arcot Blvd	Nov-Mar		Poor	P	75				1		Brine	20hp		Needs new condenser and chiller
Rivercrest	30 Harefield Drive	Nov-Mar		Poor	P	75				1		Brine	20hp		Needs new condenser and chiller
Royalcrest	50 Cabernet Circle	Nov-Mar		Fair	P	75				1		Brine	20hp		Needs new chiller

* Indicates Freon Refrigeration Plants

** Ammonia pumps direct expansion floor

Status:

Good - No major work needed
 Fair - Approx. \$50,000 work needed
 Poor - \$100,000+ work needed

Type:

D - Double = Hockey Pad & Pleasure Pad
 S - Single = Hockey Pad (with boards)
 P - Pleasure Pad (no boards)